

# Automatic Rainwater Harvesting System.

## 2500Lt Slimline, Roof Mount Controller

### Builders requirements during construction stage:

1. External copper (13mm) mains water line for water switch control
2. Weather proof GPO power point (10A)
3. Down pipe/s located within 2m of tank with a minimum of 40sq/m roof catchment
4. Flat level site suitable for tank size

It is recommended that a first flush diverter and/or leaf eater screen filter is used from connection of RWP from roof area prior to water entering your tank.

